



Facilities Design
and Construction

ADDENDUM NO. 2
TO THE
CONTRACT DOCUMENTS
MAY 12, 2025

PROJECT NO. 9558120
SESP 1P552 CATH LAB REMODEL

GENERAL

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated March 2025, and consists of pages AD2-1. The following changes, additions and/or deletions shall be made to the following documents; all other conditions shall remain the same.

ITEM NO. I – CLARIFICATIONS

Q1: Is Toilet Room IP515 on slab on grade or suspended deck?

A1: IP515 is on slab on grade

Q2: Should flooring in IP515 be replaced in its entirety or will a patch be accepted?

A2: Flooring should be replaced in its entirety.


Q3: On pdf page 34 of 1216, Cumming noted "(3) Med Gas & Vac. Piping". The N2 lines are shown to be light, not dark (new work). Are there 3 lines or 4 lines?

A3: Nitrogen is to be included as new work.

Q4: Can you please provide a better explanation for what you want included in the overhead profit %? Each of our employees could potentially have different percentages

A4: Please enter the Overhead/Profit Percentage as your firm defines it, even if it varies by job classification.

DocuSigned by:


7C3B994D0A6847E...

Casey Lubawy – Project Manager
Facilities Design & Construction
UC Davis Health